

Tag #:

For:   File           Resubmit  
          Approval    Other \_\_\_\_\_

Rep: \_\_\_\_\_  
(Company) (Project Manager)


## Outdoor Unit Drain Pan Heater



|                      |                                                               |
|----------------------|---------------------------------------------------------------|
| Power Requirements   | Wiring Harness Plugs into Outdoor Unit Control Board Terminal |
| Control Requirements | Wiring Harness Plugs into Outdoor Unit Control Board Terminal |
| Capacity (W)         | 120W                                                          |

9,000 and 12,000 Btu/h Single-Zone Cassette and Low Static Ducted Outdoor Units manufactured February 2018 and after.

1. Follow all installation instructions in the Base Pan Heater Installation manual.
2. Ensure that there is at least 1-3/16" clearance from the outdoor unit fan.
3. As a safety precaution, the heater will not energize if the outdoor temperature is higher than 32°F.
4. Appearances may vary depending on model.
5. To determine the date of the outdoor unit manufacture, refer to the first three digits of the serial number. First digit represents the year; second and third digits represent the month. For example, SN 503XXXXXX indicates date of manufacture of March 2015.



Unit : Inch