Job Name/Location:		Tag #:
Date:	For: ☐File ☐ Resubmit	
PO No.:	☐Approval ☐Other	<u></u>
Architect:	GC:	
Engr:	Mech:	
Rep:	(Project Manager)	
ANFH203B2		

20kW Electric Heat Kit

For Vertical Air Handling Units

Electrical Input:

Power Supply (V/Hz/)	(X2) 208/230V, 60Hz, 1Ph (X2)
Control	Wiring harness connects to VAHU control board

Heater Compatibility with VAHU IDUs:

Multi V	ARNUxxxNJA4; ARNUxxxNKA4
Multi F/Multi F MAX	LVNxxxHV4
Single Zone	LVNxxxHV4; LVNxxxHV

Static Pressure Drop Factors

Heater Model	Multi V IDU Static Pressure Drop (in. wc)	Single Zone and Multi F/Multi F MAX Static Pressure Drop in. wc / Downflow
ANEH203B2	-0.06	-0.04 / -0.01

Notes:

Life's Good

- 1. Must follow instructions in applicable LG installation manual.
- 2. Must follow all applicable local and national codes.
- 3. Requires separate power supply.
- 4. If a Third-Party Dry Contact and an LG internal heater or an LG Auxiliary Heater Kit is installed, supplemental heat capability cannot be controlled by the Third-Party Thermostat.

Minimum Airflow for Multi V VAHUs:

Heater Model	IDU Capacity kBtu/h (RT)	CFM	
ANEH203B2	12 (1.0)	Not Available	
ANEH203B2	18 (1.5)	Not Available	
ANEH203B2	24 (2.0)	Not Available	
ANEH203B2	30 (2.5)	Not Available	
ANEH203B2	36 (3.0)	800	
ANEH203B2	42 (3.5)	1000	
ANEH203B2	48 (4.0)	1000	
ANEH203B2	54 (4.5)	1260	

Minimum Airflow for Single Zone and Multi F/Multi F MAX VAHUs:

Heater Model	IDU Capacity kBtu/h (RT)	CFM
ANEH203B2	18 (1.5)	Not Available
ANEH203B2	24 (2.0)	Not Available
ANEH203B2	36 (3.0)	800
ANEH203B2	42 (3.5)	1000
ANEH203B2	48 (4.0)	1000

I POWER I .		Capacity	Heater Amps (Amps @ 208/230V)			Minimum Circuit Amps (Amps @ 208/230V)		
Heater Model	leater Model Supply (kW @ 208/230V)		Single	Dual Circuit		Single	Dual Circuit	
		Circuit	L1, L3	L2, L4	Circuit	L1, L3	L2, L4	
ANEH203B2	208/230V, 60Hz, 1Ph	17.3 / 20	_	41.8 / 43.5	41.8 / 43.5	-	52.3 / 54.3	52.3 / 54.3

II I . M. I.I	Circuit Breaker (Amps @ 208/230V)		Power Cable AWG³			Size of	Knockout	
1	Single Dual Circuit		Single	Dual Circuit		Conduit (inch)	Diameter (inch)	
	Circuit	L1, L3	L2, L4	Circuit	L1, L3	L2, L4	(111011)	(111011)
ANEH203B2	_	60 / 60	60 / 60	_	6/6	6/6	1-1/4	1-23/32




		/
Inh	Mama	/Location:
100	I Vallic	/ LUCATIOII.

ANEH203B2 20kW Electric Heat Kit For Vertical Air Handling Units



Tag No.: _____


PO No.: _



8-11/16

9-1/2

13-1/8



Note: Image may vary according to heater capacity.

(Unit:inch)