

Job Name/Location:

Tag #:

Date:

PO No.:

Architect:

Engr:

Rep:

(Company)

GC:

Mech:

(Project Manager)

For: File Resubmit

Approval Other



PQSH1203

Outdoor Unit Drain Pan Heater



Electrical:

Power Requirements	Wiring Harness Plugs into Outdoor Unit Control Board Terminal
Control Requirements	Wiring Harness Plugs into Outdoor Unit Control Board Terminal
Capacity (W)	120W

Compatibility:

Multi F Outdoor Units LMU180HV and LMU240HV.
--

Notes:

1. Follow all installation instructions in the Base Pan Heater Installation manual.
2. Ensure that there is at least 1-3/16" clearance from the outdoor unit fan.
3. As a safety precaution, the heater will not energize if the outdoor temperature is higher than 32°F.
4. Appearances may vary depending on model.

